Privacy-Preserved Aggregate Thermal Dynamic Model of Buildings

Zeyin Hou, Student Member, IEEE, Shuai Lu, Yijun Xu, Senior Member, IEEE, Haifeng Qiu, Wei Gu, Senior Member, IEEE, Zhaoyang Dong, Fellow, IEEE, Shixing Ding

Abstract—The thermal inertia of buildings brings considerable flexibility to the heating and cooling load, which is known to be a promising demand response resource. The aggregate model that can describe the thermal dynamics of the building cluster is an important interference for energy systems to exploit its intrinsic thermal inertia. However, the private information of users, such as the indoor temperature and heating/cooling power, needs to be collected in the parameter estimation procedure to obtain the aggregate model, causing severe privacy concerns. In light of this, we propose a novel privacy-preserved parameter estimation approach to infer the aggregate model for the thermal dynamics of the building cluster for the first time. Using it, the parameters of the aggregate thermal dynamic model (ATDM) can be obtained by the load aggregator without accessing the individual's privacy information. More specifically, this method not only exploits the block coordinate descent (BCD) method to resolve its non-convexity in the estimation but investigates the transformation-based encryption (TE) associated with its secure aggregation protocol (SAP) techniques to realize privacypreserved computation. Its capability of preserving privacy is also theoretically proven. Finally, simulation results using realworld data demonstrate the accuracy and privacy-preserved performance of our proposed method.

Index Terms-Aggregate model, buildings, demand response, nonconvex parameter estimation, privacy-preserved computation, privacy analysis.

NOMENCLATURE

A. Abbreviations

- ATDM Aggregate thermal dynamic model
- Block coordinate descent BCD
- BLA Building load aggregator
- LSR Least squares regression
- MQS Multivariate quadratic system
- SAP Secure aggregation protocol
- ΤE Transformation-based encryption
- B. Sets
- \mathbf{K} Index set of building zones
- Index set of iterations \mathbf{L}

The work was supported by the National Natural Science Foundation of China (52207080), in part by the Jiangsu Provincial Key Laboratory of Smart Grid Technology and Equipment, Southeast University, and in part by the Fundamental Research Funds for the Central Universities (Corresponding author: Shuai Lu).

Z. Hou, S. Lu, Y. Xu, W. Gu are with the Electrical Engineering Department, Southeast University, Nanjing, Jiangsu 210096, China, (e-mail: hzy17301571262@163.com; shuai.lu.seu@outlook.com; yijunxu@seu.edu.cn; wgu@seu.edu.cn).

H. Qiu and Z.Y. Dong are with the School of Electrical & Electronics Engineering, Nanyang Technological University, Singapore 639798 (e-mail: haifeng.qiu@ntu.edu.sg; zy.dong@ntu.edu.sg).

S. Ding is with the School of Cyber Science and Engineering, Southeast University, Nanjing 210096, China (e-mail: dingshx616@163.com).

- Index set of model order \mathbf{M}
- \mathbf{T} Index set of time periods

C. Parameters and Variables

- $(\cdot)^{[i]}$ The *i*-th column of matrix (\cdot)
- $\alpha_{(.)}, \beta_{(.)}, \gamma_{(.)}, \theta_{(.)}$ Parameters of the ATDM
- Penalty factor λ
- Indoor temperature of building zone i at period t
- Impact of occupants' activities at period t
- $\tau_{in,z}^{i,t}$ $\tau_{occ,bc}^{t}$ τ_{out}^{t} Outdoor temperature at period t
- (\cdot) The masked version of (\cdot) after implementing the SAP method
- Aggregate indoor temperature of building cluster at $\tilde{\tau}_{in.bc}^t$ period t
 - Random error
 - Aggregation coefficient of building zone i
 - Heating/cooling power of building zone i at period t
- $\begin{array}{c} \xi^i_{bc} \\ h^{i,t}_{load,z} \\ h^t_{rad} \\ \xi \end{array}$ Solar radiation power at period t
- K, iThe total number of zones in the building cluster and its index
- L, lThe total number of iterations and its index
- M, mModel order and its index
- T, tThe total number of period and its index
 - Random matrix

W

I. INTRODUCTION

THE heating and cooling demands of buildings take up a large proportion of energy consumption [1], playing an important role in the energy system. The inherent storage capacity of buildings brings considerable flexibility to the heating and cooling demands [2], which is vital for the operation and control of the energy system [3], [4]. Therefore, a thermal dynamic model that can accurately describe the relationship between control and state variables of buildings is a must [5].

Apparently, establishing an accurate model for each building facilitates the refined control of heating and cooling power. However, due to prohibitive computation complexity and heavy communication burden, it is impractical for the energy system to interact with numerous buildings in a peer-to-peer way directly. In practice, the buildings in one area are usually clustered to access the energy system in an aggregated manner. Hence, an aggregate model that can describe the overall thermal dynamics of the building cluster is an important interface with the energy system [6].

In existing research, three different approaches have been proposed to obtain the aggregate model of the building cluster, including the physics-based method, the data-driven method [7], [8], and the hybrid approach [9]. The physics-based method builds thermal behavior modeling based on solving equations of energy conversion law [10]. It is overall more accurate than other models but has high model complexity. The data-driven method typically involves linear regressions [11], artificial neural network [12], etc. Although suitable for the unclear physical model, it requires a large quantity and high quality of data while exhibiting poor interpretability. The hybrid method couples the physics-based method and the data-driven method, overcoming their respective drawbacks to a certain extent, like the aggregate thermal dynamic model (ATDM) [7] and resistance-capacitance model designed for buildings [13]. Therefore, the hybrid method is gaining increasing popularity in aggregate modeling.

For the latter two data-related methods, with the aggregator, e.g., the building load aggregator (BLA), assumed to calculate the aggregate model of the building cluster using the real indoor temperature and heating/cooling power information of each building (zone) as most existing literature suggested [7], [14], the users' private information faces a severe risk of disclosure. More seriously, once this information is disclosed, the BLA may manipulate the heat/cooling energy price to gain more benefits at the expense of users. Therefore, privacy concern is an unavoidable problem in the aggregate modeling of the building cluster. It is urgent to develop a privacypreserved computation approach for the aggregate modeling of the building cluster. Therefore, this is chosen as the focus of our article.

Here, for the privacy-preserved computing problem, numerous methods have been exploit. Typical examples involve the alternating direction method of multipliers (ADMM), differential privacy (DP) method, homomorphic encryption (HE) method, and transformation-based encryption (TE) method [15]. Among them, the ADMM is a decomposition-based algorithm that could protect privacy to some extent but requires the exchange of intermediate information during iterations [16], [17]. It leads to serious privacy disclosure in many situations [18], which have been revealed in the source location problem [19], the agreement problem [20] and the regression problem [21]. The DP technique protects privacy by adding customized noise to the private data. For example, Dvorkin et al. [22] initiate the DP-based optimal power flow (OPF) problem. Wang et al. [23] propose the DP-based consensus + innovations method to realize the distributed parameter estimation while preserving the private information of agents. Although this DP method protects privacy to some extent, it essentially alternates the original optimization problem, resulting in an inevitable loss of the optimality [24]. Alternatively, the HE allows computations to be performed on the encrypted data. For instance, Wu et al. propose a privacy-preserved distributed OPF algorithm based on partially homomorphic encryption [25]. Chen et al. [26] advocate the HE fitting the coefficients of ridge linear regression. Despite the robustness of HE to privacy attacks, the extremely high computational complexity hinders its practical application [15], [27]. Besides, some researchers have proposed the TE technique, which can transform the original model into its equivalent data-masked one through masking using random matrices. Moreover, Tian *et al.* [28] propose the TE-based method to solve the privacypreserved mixed-integer quadratic optimization problem for energy management. Karaca *et al.* [29] offer the TE approach to tackle data privacy problems of both primal and dual variables in a collaborative network revenue management problem. Jia *et al.* [30] use the TE technique to solve chance-constrained optimal power flow with private information among agents.

Although the above-mentioned privacy-preserved computation methods have made many advances in the energy optimization field, developing a privacy-preserved aggregate modeling method for buildings has barely received attention. Particularly, the parameter estimation of the aggregate model of buildings is a nonconvex optimization problem [7]. It is difficult to directly apply these privacy-preserved methods that mainly focus on convex optimization problems [29], [30] that is unsuitable for the aggregate modeling of buildings.

Thus, we are motivated to design a privacy-preserved computation method for the aggregate thermal dynamic model (ATDM) of the building cluster. Based on this method, the BLA can estimate the parameters of the ATDM without knowing the real indoor temperature and heating/cooling power of users. We also prove that, under very mild assumptions, the BLA cannot infer the private information of the users.

The main contributions are summarized as follows.

- We propose a privacy-preserved algorithm for the aggregate modeling of the building cluster. This method can estimate the parameters of the ATDM without exposing the privacy information of users, such as the indoor temperature and heating/cooling power.
- 2) As far as we know, we initiate the study of the nonconvex parameter estimation problem with privacy-preservation. We exploit the block coordinate descent (BCD) method to handle the non-convexity and the TE and security aggregation protocol (SAP) methods to mask the privacy information of users.
- 3) We provide a detailed privacy analysis for the proposed method. We reveal that the essence of the privacy inferences of this method is solving multivariate quadratic systems (MQS), which is an NP-hard problem having multiple solutions. This theoretically ensures the privacy preservation performance of the proposed method.

The rest of this paper is organized as follows. Section II introduces the ATDM for the building cluster and the corresponding parameter estimation method. Section III proposes the privacy-preserved parameter estimate algorithm. Section IV carries out the privacy analysis for the proposed algorithm. Section V gives the numerical simulation results, and Section VI concludes this paper.

II. PROBLEM DESCRIPTION

Usually, there are two different load control modes for buildings, i.e., the direct and indirect load control [7], depending on whether the energy system controls the heating/cooling power of each building zone (direct) or the total heating/cooling power of the building (indirect). In this paper, we formulate the proposed privacy-preserved ATDM based on direct load



Fig. 1. Concept of the Aggregation of the building cluster.

control, which can be extended to the indirect one. For the sake of generality, we use "agent" below to refer to the building zone or the building. In the following, we introduce the ATDM of the building cluster that was initially proposed in [7]. Then, we present the parameter estimation model of the ATDM without privacy preservation.

A. Aggregate Thermal Dynamic Model

The aggregate model of the building cluster under direct control is illustrated in Fig. 1, which aims to select a proper state variable to represent the overall characteristics, i.e., the aggregate state. First, following traditions [7], [31], [32], we introduce the M-order linear time-invariant dynamic system to describe the thermal dynamic evolution of the agent as

$$\tau_{in,z}^{t} = \sum_{m \in \mathbf{M} \setminus \{0\}} \alpha_{z}^{m} \tau_{in,z}^{t-m} + \sum_{m \in \mathbf{M}} \beta_{z}^{m} h_{load,z}^{t-m} + \sum_{m \in \mathbf{M}} \gamma_{z}^{m} \tau_{out}^{t-m} + \sum_{m \in \mathbf{M}} \theta_{z}^{m} h_{rad}^{t-m} + \tau_{occ}^{t}, \ \forall t \in \mathbf{T},$$
⁽¹⁾

wherein $\mathbf{M} = [0, \dots, M]$ and $\mathbf{T} = [1, \dots, T]$. Considering that occupant activities are usually periodical, τ_{occ}^t is set to a time series with a period of T_{occ} .

Then, we use the linear aggregation method proposed in [7] to derive the aggregate state. From the perspective of energy, the aggregate state should be able to quantify the energy storage in the buildings as

$$c_{heat} \sum_{k \in \mathbf{K}} m_z^i \tilde{\tau}_{in,bc}^t = c_{heat} \sum_{u \in \mathbf{K}} m_z^i \tau_{in,z}^{k,t}, \qquad (2a)$$

wherein $\mathbf{K} = [1, \dots, K]$, c_{heat} is the heat capacity of air, and m_z^k is the air mass of agent *i*.

Denote $\xi_{bc}^i = m_z^i / \sum_{i \in \mathbf{K}} m_z^i$ as the aggregation coefficient of the zone *i*. Then, we can define the aggregate state based on (2a) using the aggregation equation [7] as

$$\tilde{\tau}_{in,bc}^{t} = \sum_{i \in \mathbf{K}} \xi_{bc}^{i} \tau_{in,z}^{i,t}.$$
(2b)

According to the physical meaning of the aggregation coefficient given in (2a), ξ_{bc}^i satisfies

$$\sum_{i \in \mathbf{K}} \xi_{bc}^i = 1, \quad \xi_{bc}^i \ge 0, \ \forall i \in \mathbf{K}.$$
 (2c)

Finally, by using the aggregate state, $\tilde{\tau}_{in,bc}^t$, to represent the state of the building cluster, we get the ATDM of the building

cluster as

$$\tilde{\tau}_{in,bc}^{t} = \sum_{m \in \mathbf{M} \setminus \{0\}} \alpha_{bc}^{m} \tilde{\tau}_{in,bc}^{t-m} + \sum_{m \in \mathbf{M}} \sum_{i \in \mathbf{K}} \beta_{bc}^{m} h_{load,z}^{i,t-m} + \sum_{m \in \mathbf{M}} \gamma_{bc}^{m} \tau_{out}^{t-m} + \sum_{m \in \mathbf{M}} \theta_{bc}^{m} h_{rad}^{t-m} + \tau_{occ,bc}^{t}, \ \forall t \in \mathbf{T},$$
(2d)

This model describes the relationship between the heating/cooling power $h_{load,z}^{i,t}$ and the aggregate state $\tilde{\tau}_{in,bc}^t$ of the building cluster, which can be directly used by energy systems for operation and control.

B. Parameter Estimation Model

Combining the aggregation equation (2b) and the ATDM (2d), we obtain the measurement equation as

$$\sum_{i \in \mathbf{K}} \xi_{bc}^{i} \tau_{in,z}^{i,t} = \sum_{m \in \mathbf{M} \setminus \{0\}} \sum_{i \in \mathbf{K}} \alpha_{bc}^{m} \xi_{bc}^{i} \tau_{in,z}^{i,t-m} + \sum_{m \in \mathbf{M}} \sum_{i \in \mathbf{K}} \beta_{bc}^{m} h_{load,z}^{i,t-m} + \sum_{m \in \mathbf{M}} \gamma_{bc}^{m} \tau_{out}^{t-m} + \sum_{m \in \mathbf{M}} \theta_{bc}^{m} h_{rad}^{t-m} + \tau_{occ,bc}^{t} + \varepsilon^{t}, \ \forall t \in \mathbf{T}.$$
(3)

Here, given $\{\tau_{in,z}^{i,t-m}, h_{load,z}^{i,t-m}, \tau_{out}^{t-m}, h_{rad}^{t-m}\}\ (\forall m \in \mathbf{M}, i \in \mathbf{K}, t \in \mathbf{T})$, we can use the least squares regression (LSR) method to estimate the model parameters $\{\xi_{bc}^{i}, \alpha_{bc}^{m}, \beta_{bc}^{m}, \gamma_{bc}^{m}, \theta_{bc}^{m}, \tau_{occ,bc}^{t}\}\ (\forall m \in \mathbf{M}, i \in \mathbf{K}, t \in \mathbf{T})$ for independent and identically distributed Gaussian errors, $\varepsilon^{t}, t \in \mathbf{T}$. Then, let us denote $\xi = [\xi_{bc}^{1}, \cdots, \xi_{bc}^{K}]^{T} \in \mathbb{R}^{K \times 1}, \alpha = [\alpha_{bc}^{1}, \cdots, \alpha_{bc}^{M}]^{T} \in \mathbb{R}^{M \times 1}, \beta = [\beta_{bc}^{0}, \cdots, \beta_{bc}^{M}]^{T} \in \mathbb{R}^{(M+1) \times 1}, \gamma = [\gamma_{bc}^{0}, \cdots, \gamma_{bc}^{M}]^{T} \in \mathbb{R}^{(M+1) \times 1}, \theta = [\theta_{bc}^{0}, \cdots, \theta_{bc}^{M}]^{T} \in \mathbb{R}^{(M+1) \times 1}, \tau_{occ} = [\tau_{occ}^{1}, \cdots, \tau_{occ}^{T}]^{T} \tau_{out}^{-m} = [\tau_{out}^{1-m}, \cdots, \tau_{out}^{T-m}]^{T} \in \mathbb{R}^{T \times 1}, h_{rad}^{-m} = [h_{rad}^{1-m}, \cdots, h_{rad}^{T-m}]^{T} \in \mathbb{R}^{T \times 1},$

$$h_{load,z}^{-m} = \begin{bmatrix} h_{load,z}^{1,1-m} & \cdots & h_{load,z}^{K,1-m} \\ \vdots & \ddots & \vdots \\ h_{load,z}^{1,T-m} & \cdots & h_{load,z}^{K,T-m} \end{bmatrix} \in \mathbb{R}^{T \times K},$$
$$\tau_{in,z}^{-m} = \begin{bmatrix} \tau_{in,z}^{1,1-m} & \cdots & \tau_{in,z}^{K,1-m} \\ \vdots & \ddots & \vdots \\ \tau_{in,z}^{1,T-m} & \cdots & \tau_{in,z}^{K,T-m} \end{bmatrix} \in \mathbb{R}^{T \times K}.$$

Also, to avoid the sparsity of the aggregation coefficients, ξ , and to address the inherent colinearity among the indoor temperature, we further add the L_2 regularization term in the LSR as

$$\min_{\substack{\xi,\alpha,\beta,\gamma,\tau_{occ}}} f(\xi,\alpha,\beta,\gamma,\theta,\tau_{occ}) \\
= \|c_0\xi - c_1(I_M \otimes \xi)\alpha - c_2\beta - c_3\gamma \\
-c_4\theta - \tau_{occ}\|_2^2 + \lambda \|\xi\|_2^2 \\
\text{s.t.} \quad \xi \ge 0, \ 1^T\xi = 1,$$
(4)

wherein $f(\cdot)$ is the objective function accounting for the sum of squared residuals as well as L_2 regularization term; λ is the penalty factor; 1_K is the K-dimensional 1-vector; I_x is the x-dimensional identity matrix; and \otimes is the Kronecker product. The constants coefficient matrices $c_0 - c_4$ are defined as $c_0 = \tau_{in,z}^{-0} \in \mathbb{R}^{T \times K}$, $c_1 = [\tau_{in,z}^{-1}, \cdots, \tau_{in,z}^{-M}] \in \mathbb{R}^{T \times KM}$, $c_2 = [h_{load,z}^{-0} \mathbf{1}_K, \cdots, h_{load,z}^{-M} \mathbf{1}_K] \in \mathbb{R}^{T \times (M+1)}$, $c_3 = [\tau_{out}^{-0}, \cdots, \tau_{out}^{-M}] \in \mathbb{R}^{T \times (M+1)}$, $c_4 = [h_{rad}^{-0}, \cdots, h_{rad}^{-M}] \in \mathbb{R}^{T \times (M+1)}$; and \otimes is the Kronecker product.

Remark 1. The model (4) is a nonconvex optimization problem with a nonconvex objective and linear constraints. Currently, there are no computationally effective methods to obtain the global optimum. Fortunately, one reasonable local optimum is acceptable for the parameter estimation problem. Besides, the existing research on privacy-preserved computation mainly focuses on convex optimization problems, such as linear and quadratic optimization, which cannot be directly applied to this problem.

III. PRIVACY-PRESERVED ALGORITHM

In this section, we propose the privacy-preserved algorithm for the model (4). First, we provide the preliminaries on the privacy definition and related methods. Second, we use the BCD method to decouple the model (4) into two convex subproblems to tackle the non-convexity. Then, we present the privacy-preserved computation methods for the subproblems.

A. Preliminaries

1) Privacy Definition: The indoor temperature, $\tau_{in,z}^{i,t}$, $(\forall i \in \mathbf{K}, \forall t \in \mathbf{T}, \text{ and heating/cooling power, } h_{load,z}^{i,t}, (\forall i \in \mathbf{K}, \forall t \in \mathbf{T})$, are defined as the private information of the user *i*.

2) Secure Aggregation Protocol: The SAP involves two types of entities: a computing center that performs aggregation operations and a set U composed of several users, where each user *i* owns its private information, $x_i \in \mathbb{R}^{T \times 1}$. To guarantee that the computing center only acquires the summation, $\sum_{i \in U} x_i$, without knowing private information, x_i , the following steps are implemented:

(1) Each pair of users (i, j) shares a random vector $s_{i,j} \in \mathbb{R}^{T \times 1}$.

(2) User *i* masks its private information, x_i , with the random vectors it receives to get the masked information, \tilde{x}_i , as

$$\tilde{x}_i = x_i + \sum_{j \in \mathbf{U}, j > i} s_{i,j} - \sum_{j \in \mathbf{U}, j < i} s_{j,i}.$$
 (5a)

(3) Each user sends the masked information, $\tilde{x_i}$, to the computing center, and the computing center calculates the summation of the masked information, denoted as z as

$$z = \sum_{i \in \mathbf{U}} \tilde{x}_i = \sum_{i \in \mathbf{U}} x_i.$$
(5b)

Note that the SAP can be extended to the situation where x_i is a matrix of any dimension as long as the random $s_{i,j}$ keeps the same dimension as x_i .

3) Transformation-based Encryption: We take the unconstrained linear programming problem among multi-agents as an example to illustrate the TE method, defined as

$$\min_{x} c^T x, \tag{6a}$$

wherein $x = [x_1, \dots, x_K]^T \in \mathbb{R}^{T \times 1}$, $c = [c_1, \dots, c_K]^T \in \mathbb{R}^{K \times 1}$. In this problem, c_i is the private information belonging to agent *i*, and x_i is its associated decision variable. The computing center needs *c* to implement the optimization calculation. The fundamental idea of the TE method is to mask the input data through a random matrix, including additive randomization and multiplicative randomization. In this work, multiplicative randomization is used, and the following steps are implemented.

(1) Each agent generates a random column vector $W^{[i]} = [w_{1i}, \cdots, w_{Ki}]^T \in \mathbb{R}^{K \times 1}$ as the encryption matrix, only known to itself. Denote $W = [W^{[1]}, \cdots, W^{[K]}] \in \mathbb{R}^{K \times K}$.

(2) Each agent uploads the product, $c_i(\vec{W}^{[i]})^T$, to the computing center. Then, the computing center calculates the summation, $\sum_{i \in \mathbf{K}} c_i(W^{[i]})^T$, and constructs the equivalent optimization problem in (6b),

$$\min_{\bar{x}} c^T W^T \bar{x},\tag{6b}$$

where $\bar{x} \in \mathbb{R}^{K \times 1}$ is the encrypted decision vector.

(3) The computing center solves the optimization problem (6b) to get \bar{x} , and then broadcasts \bar{x} to all agents. Then, the agent *i* can recover its decision variable according to the recovery equation as

$$x_i = (W^{[i]})^T \bar{x}. \tag{6c}$$

Remark 2. The TE technique can be applied to the parameter estimation problem by taking the decision variables in (6a) as the parameters to be estimated.

B. The BCD-Based Iterative Algorithm

The existing privacy-preserved computation methods usually cannot be directly applied to the model (4) because of the nonconvex objective. Fortunately, this problem is easy to decompose. Specifically, the model (4) turns into a quadratic programming problem once the variables ξ or α are fixed, for which some existing privacy-preserved computation techniques can be used. Inspired by this, we use the BCD method to decouple the model (4) into a ξ -fixed problem and a α -fixed problem as

$$SP_{I}(\xi): \min_{\alpha,\beta,\gamma,\theta,\tau_{occ}} f(\xi,\alpha,\beta,\gamma,\theta,\tau_{occ}),$$
(7a)

$$SP_{II}(\alpha): \min_{\substack{\xi,\beta,\gamma,\theta,\tau_{occ}}} f(\xi,\alpha,\beta,\gamma,\theta,\tau_{occ})$$

s.t. $\xi \ge 0, \ 1^T \xi = 1.$ (7b)

Theoretically, the local optimum of the model (4) can be obtained by solving (7a) and (7b) iteratively. As indicated in (4), the privacy information in the two subproblems includes c_0 , c_1 , and c_2 . We only focus on protecting c_0 and c_1 in the following for conciseness, since c_2 can be protected the same way as section III-C does through the SAP method.

C. Privacy-Preserved Computation for $SP_I(\xi)$

In SP_I(ξ), since ξ is known and can be transferred to the users, the privacy of c_0 and c_1 equals that of $c_0\xi$ and $c_1(I_M \otimes \xi)$. Note that $c_0\xi$ and $c_1(I_M \otimes \xi)$ have a summation form, so we propose the SAP-based computation procedure as follows.

- 1) The BLA transfers ξ_i to the agent $i, \forall i \in \mathbf{K}$.
- 2) The agent *i* calculate s_i^{-m} , as

$$s_i^{-m} = \xi_i(\tau_{in,z}^{-m})^{[i]}, \ \forall i \in \mathbf{K}, \forall m \in \mathbf{M},$$
(8a)

3) The agent *i* generates random vectors $r_{i,j}^{-m} \in \mathbb{R}^{T \times 1}, \forall m \in \mathbf{M}, \forall i \in \mathbf{K}$, and transfer them to $j, \forall i < j \leq K$. Afterwards, the agent *i* perform the following computation

$$\tilde{s}_i^{-m} = s_i^{-m} + \sum_{j>i} r_{i,j}^{-m} - \sum_{j (8b)$$

- The agent *i* send the masked private information s̃_i^{-m} to the BLA, ∀*i* ∈ K.
- 5) The BLA calculates $c_0\xi$ and $c_1(I_M \otimes \xi)$ using $\tilde{s}_i^{-m}, \forall i \in \mathbf{K}, m \in \mathbf{M}$, as

$$c_0\xi = \tau_{in,z}^{-0}\xi = \sum_{i \in \mathbf{K}} s_i^{-0} = \sum_{i \in \mathbf{K}} \tilde{s}_i^{-0},$$
(8c)

$$c_{1}(\mathbf{I}_{M} \otimes \xi) = \begin{bmatrix} \tau_{in,z}^{-1}\xi, \cdots, \tau_{in,z}^{-M}\xi \end{bmatrix}$$
$$= \begin{bmatrix} \sum_{i \in \mathbf{K}} \tilde{s}_{i}^{-1}, \cdots, \sum_{i \in \mathbf{K}} \tilde{s}_{i}^{-M} \end{bmatrix}, \qquad (8d)$$

and then solve $SP_{I}(\xi)$ to obtain $\alpha(\xi)$, $\beta(\xi)$, $\gamma(\xi)$, $\theta(\xi)$, and $\tau_{occ}(\xi)$.

Remark 3. Obviously, the SAP method also applies to c_2 since its element has the summation form, i.e., $h_{load,z}^{-m} \mathbf{1}_K$, in which the agent *i* only needs to generate extra random vectors to mask $(h_{load,z}^{-m})^{[i]}, \forall m \in \mathbf{M}$. Hence, we do not detail the privacy preservation method of c_2 for conciseness.

D. Privacy-Preserved Computation for $SP_{II}(\alpha)$

We assume that the BLA transfers α to each agent. Define

$$\hat{\tau}_{in,z} \triangleq \tau_{in,z}^{-0} - \sum_{m \in \mathbf{M} \setminus \{\mathbf{0}\}} \alpha_{bc}^m \tau_{in,z}^{-m} \in \mathbb{R}^{T \times K}, \qquad (9a)$$

and then we have

$$f(\xi, \alpha, \beta, \gamma, \theta, \tau_{occ}) = \|\hat{\tau}_{in,z}\xi - c_2\beta - c_3\gamma - c_4\theta - \tau_{occ}\|_2^2 + \lambda \|\xi\|_2^2.$$
(9b)

After the agent *i* receives α , it can calculate $\hat{\tau}_{in,z}^{[i]}$ that is needed to solve SP_{II}(α). However, if the BLA knows $\hat{\tau}_{in,z}$, it can infer the privacy information $\tau_{in,z}^{-m}$ ($\forall m \in \mathbf{M}$) of users. Our detailed proof of this is given in Appendix A. Hence, in the following, we propose the TE-based method to mask $\hat{\tau}_{in,z}$.

We assume that ξ can be obtained based on $\overline{\xi}$ through a linear transformation as

$$\xi = W^T \bar{\xi},\tag{10a}$$

wherein

$$W = \begin{bmatrix} W^{[1]} & \cdots & W^{[K]} \end{bmatrix} = \begin{bmatrix} w_{11} & \cdots & w_{1K} \\ \vdots & \ddots & \vdots \\ w_{K1} & \cdots & w_{KK} \end{bmatrix}. \quad (10b)$$

In (10b), $W^{[i]}$ is the random matrix belonging to the agent *i*. Then, SP_{II}(α) can be represented as

$$\min_{\bar{\xi},\beta,\gamma,\theta,\tau_{occ}} f(\bar{\xi},\beta,\gamma,\theta,\tau_{occ}) = \|\hat{\tau}_{in,z}W^T\bar{\xi} - c_2\beta \\
-c_3\gamma - c_4\theta - \tau_{occ}\|_2^2 + \lambda\bar{\xi}^TWW^T\bar{\xi} \\
\text{s.t.} \quad W^T\bar{\xi} \ge 0, 1^TW^T\bar{\xi} = 1.$$
(11)

To solve (11), the BLA needs to know the three uploads from agents, namely $\hat{\tau}_{in,z}W^T$, WW^T , and 1^TW^T . Note that W cannot be known by the BLA; otherwise, the BLA can probably infer $\hat{\tau}_{in,z}$ by combining $\hat{\tau}_{in,z}W^T$ and W^T , and can further $\tau_{in,z}^{i,t}$ ($\forall i \in \mathbf{K}, \forall t \in \mathbf{T}$). Therefore, each agent i cannot directly upload $W^{[i]}$ to the BLA. This is where the SAP method comes into play. We notice $\hat{\tau}_{in,z}W^T$, WW^T , and 1^TW^T can be reformulated into summation forms as

$$\hat{\tau}_{in,z} W^T = \sum_{i \in \mathbf{K}} \hat{\tau}_{in,z}^{[i]} (W^{[i]})^T,$$
 (12a)

$$WW^T = \sum_{i \in \mathbf{K}} W^{[i]} (W^{[i]})^T.$$
 (12b)

$$\mathbf{L}^T W^T = \sum_{i \in \mathbf{K}} (W^{[i]})^T, \qquad (12c)$$

Hence, by denoting $A_1^i = \hat{\tau}_{in,z}^{[i]} (W^{[i]})^T \in \mathbb{R}^{T \times K}$ and $A_2^i = W^{[i]} (W^{[i]})^T \in \mathbb{R}^{K \times K}$, the SAP method can be implemented as

$$\tilde{A}_{1}^{i} = A_{1}^{i} + \sum_{j \in \mathbf{K}, j > i} u_{i,j} - \sum_{j \in \mathbf{K}, j < i} u_{j,i},$$
 (13a)

$$\tilde{A}_{2}^{i} = A_{2}^{i} + \sum_{j \in \mathbf{K}, j > i} p_{i,j} - \sum_{j \in \mathbf{K}, j < i} p_{j,i},$$
 (13b)

$$\tilde{W}^{[i]} = W^{[i]} + \sum_{j \in \mathbf{K}, j > i} q_{i,j} - \sum_{j \in \mathbf{K}, j < i} q_{j,i},$$
(13c)

where $u_{i,j} \in \mathbb{R}^{T \times K}$, $p_{i,j} \in \mathbb{R}^{K \times K}$, and $q_{i,j} \in \mathbb{R}^{K \times 1}$ are the random matrices generated by the agent *i*.

It is worth pointing out that the agent *i* cannot directly upload A_1^i and A_2^i to the BLA. Once it occurs, the BLA can infer the proportional relationship of each element in $M^{[i]}$, and further infer $w_{i,j}$ ($\forall i, j \in \mathbf{K}$) based on $\xi = W^T \bar{\xi}$. To illustrate this, we take what will happen when A_2^i is disclosed to the BLA as an example. The details can be found in Appendix B. Besides, the constraint $W^T \bar{\xi} \ge 0$ in (11), originated from $\xi \ge 0$, is a tricky problem since the BLA cannot know the value of W. Fortunately, the simulation results indicate $\xi \ge 0$ always holds even if we remove it from $SP_{II}(\alpha)$. Physically, this constraint ensures that the contribution of each zone to the aggregate state is not negative, which is obviously established.

Finally, we obtain the transformed model for $SP_{II}(\alpha)$ as

$$\min_{\bar{\xi},\beta,\gamma,\theta,\tau_{occ}} f(W^T \bar{\xi},\alpha,\beta,\gamma,\theta,\tau_{occ}) = \left\| \left(\sum_{i \in \mathbf{K}} \tilde{A}_1^i \right) \bar{\xi} - c_2 \beta - c_3 \gamma - c_4 \theta - \tau_{occ} \right\|_2^2 + \lambda \bar{\xi}^T \left(\sum_{i \in \mathbf{K}} \tilde{A}_2^i \right) \bar{\xi} \\$$
s.t. $\left(\sum_{i \in \mathbf{K}} \tilde{W}^{[i]} \right) \bar{\xi} = 1.$
(14)

Now, the privacy-preserved computation procedure for $SP_{II}(\alpha)$ is given as follows.

Algorithm 1:	Privacy-preserved	l Algorithm f	for ATDM
--------------	-------------------	---------------	----------

Input: $h_{load,z}^{-m}$, τ_{out}^{-m} , h_{rad}^{-m} , $\forall m \in \mathbf{M}$ **Output:** the final solution and the objective function 1 The BLA set tolerance δ , initialize $\xi^{(0)}$, l = 0, and $GAP = +\infty$; the BLA distributes $\xi_{i}^{(0)}$ to agent i;

- 2 while $GAP \ge \delta$ do
- 3 Each agent *i* generates random vector $r_{i,j}^{-m,(l)}$, sends it to agent *j*, and calculates $\tilde{s}_i^{-m,(l)}$ and sends it to the BLA;
- 4 The BLA calculates $\sum_{i=1}^{K} \tilde{s}_{i}^{-m,(l)}$, solve SP_I(ξ), get the optimal solution f_{1} and $\alpha^{(l+1)}$;
- 5 The BLA sends $\alpha^{(l+1)}$ to each agent ;
- 6 Each agent *i* generates random matrices $W^{[i],(l)}$, $u^{(l)}_{i,j}, p^{(l)}_{i,j}$ and $q^{(l)}_{i,j}$. Each agent *i* calculates $\tilde{A}^{i,(l)}_1$, $\tilde{A}^{i,(l)}_2$ and $\tilde{W}^{[i],(l)}$ separately and sends them to the BLA;
- 7 The BLA solve the transformed SP_{II}(α) in (14), get the optimal solution f_2 and $\bar{\xi}^{(l+1)}$;
- 8 The BLA distributes $\bar{\xi}^{(l+1)}$ to the agent *i*;
- 9 Each agent *i* calculates $\xi_{bc}^{i,(l+1)}$ according to $\xi_{bc}^{i,(l+1)} = (W^{[i],(l)})^T \bar{\xi}^{(l+1)}$, and sent $\xi_{bc}^{i,(l+1)}$ back to the BLA;
- 10 The BLA calculates the GAP:

$$GAP = \min \left\{ f_1 - f_2, (f_1 - f_2)/f_2 \right\};$$

$$l = l + 1;$$

11 end

- 1) The BLA broadcast α to each agent.
- 2) The agent *i* calculates $\hat{\tau}_{in,z}^{[i]}$ based on (9a), $\forall i \in \mathbf{K}$.
- 3) The agent *i* generates random matrices (vectors) $W^{[i]}$, $u_{i,j}$, $p_{i,j}$, and $q_{i,j}$, and transfers $u_{i,j}$, $p_{i,j}$, and $q_{i,j}$ to other zones. $(i < j \le K)$.
- other zones. (i < j ≤ K).
 4) The agent i calculates Â₁^[i], Â₂^[i], and W̃^[i] based on (13a)-(13c), and then transfers them to the BLA.
- 5) The BLA solves the problem (14) to obtain $\bar{\xi}(\alpha)$, $\beta(\alpha)$, $\gamma(\alpha)$, $\theta(\alpha)$, and $\tau_{occ}(\alpha)$, and then broadcasts $\bar{\xi}(\alpha)$ to each agent.
- 6) The agent *i* calculates $\xi_{bc}^i = (W^{[i]})^T \bar{\xi}(\alpha)$, and then return ξ_{bc}^i to the BLA.

E. Flowchart of the Proposed Algorithm

The flowchart of the proposed privacy-preserved algorithm is given in Algorithm 1. The information exchange process of the algorithm is shown in Fig. 2. Here, we suppose that the agents are independent entities that can communicate with other agents and the BLA. The algorithm can be easily ported to the system between the buildings and the BLA by considering the buildings as independent entities. Note that in the proposed algorithm, the BLA needs to solve the variants of $SP_I(\xi)$ and $SP_{II}(\alpha)$ in Step 4 and Step 7, respectively, which are both quadratic programming problem that can be solved by many off-the-shelf software.



Fig. 2. Information exchange of the proposed algorithm. The blue arrows between the BLA block and the building cluster block represent the interactive information within these two entities. The blue arrows within the building cluster block denote the intermediate information between two agents that is necessary for SAP. The red arrows represent the algorithm procedures performed between information transformations, among which the first two belong to $SP_{II}(\xi)$ and the others belong to $SP_{II}(\alpha)$.

IV. PRIVACY ANALYSIS

In this section, privacy analysis will be carried out for the proposed privacy-preserved ATDM. First, for the BLA to make privacy inferences, it has to aggregate the received information to offset the random matrices introduced by the SAP method. Second, we divide the effective information for privacy inferences into three categories, i.e., only τ -related information, only W-related information, and $\{\tau, W\}$ -related information. Then, we analyze the impossibility of inferring privacy information based on only τ -related or only W-related information. Finally, we clarify that the essence of privacy inferences in our proposed algorithm is to solve the MQS problem, which is NP-hard. We start with a lemma to illustrate the privacy security of the SAP method.

Lemma 1. In the SAP method, random masks hide all information about users' individual privacy information except for their sum.

We omit the proof of Lemma 1. The relative analysis can be found in [33].

Remark 4. Lemma 1 conveys a basic idea that once the BLA tends to make privacy inferences, it has to aggregate the information uploaded by agents to eliminate the substantial random variables introduced by SAP. Thus, the BLA needs to aggregate the received information $\tilde{s}_i^{-m}(\forall i \in \mathbf{K}, \forall m \in \mathbf{M})$ in $\mathrm{SP}_{\mathrm{I}}(\xi)$ and \tilde{A}_1^i , \tilde{A}_2^i as well as $\tilde{W}^{[i]}$ ($\forall i \in \mathbf{K}$) in $\mathrm{SP}_{\mathrm{II}}(\alpha)$ to get aggregate information $\tau_{in,z}^{-m}\xi$ ($\forall m \in \mathbf{M}$), $\hat{\tau}_{in,z}W^T$, WW^T and 1^TW^T for privacy inferences. Besides, the relationship between ξ and $\bar{\xi}$, i.e., $\xi = W^T \bar{\xi}$, is also valuable for the BLA to make privacy inferences. This relationship information is caused by implementing the 7th step of our proposed algorithm.

Denote $\tau_{in,z}^{-m} \xi^{(l)}$ as $d_{1,m}^{(l)} \in \mathbb{R}^{T \times 1}$, $(W^{(l)}W^{(l)})^T$ as $D_1^{(l)} \in \mathbb{R}^{K \times K}$, $\mathbf{1}^T (W^{(l)})^T$ as $d_2^{(l)} \in \mathbb{R}^{K \times 1}$ and $\hat{\tau}_{in,z} (W^{(l)})^T$ as

 $D_2^{(l)} \in \mathbb{R}^{T \times K}$. Then, We divide the effective information for privacy inferences into three types:

1) Type-1 information: only τ -related information

$$\mathbf{I}_{\tau}^{(l)} \triangleq \left\{ \tau_{in,z}^{-m} \mid \tau_{in,z}^{-m} \xi^{(l)} = d_{1,m}^{(l)}, m \in \mathbf{M} \right\}$$
(15a)

2) Type-2 information: only W-related information

$$\mathbf{I}_{W}^{(l)} \triangleq \left\{ W^{(l)} \mid W^{(l)}(W^{(l)})^{T} = D_{1}^{(l)}, \\
\mathbf{1}^{T}(W^{(l)})^{T} = d_{2}^{(l)}, (W^{(l)})^{T} \bar{\xi}^{(l)} = \xi^{(l)} \right\}$$
(15b)

3) Type-3 information: $\{\tau, W\}$ -related information

$$I_{\tau,W}^{(l)} \triangleq \left\{ \tau_{in,z}^{-m}, W^{(l)}, m \in \mathbf{M} \mid \right. \\ \left(\tau_{in,z}^{-0} - \sum_{m \in \mathbf{M} \setminus \{\mathbf{0}\}} \alpha_{bc}^{m} \tau_{in,z}^{-m}) (W^{(l)})^{T} = D_{2}^{(l)} \right\}$$
(15c)

wherein $l \in \mathbf{L}$ is the iteration index. Type-1 information is only useful for inferring indoor temperatures, $\tau_{in,z}^{-m}$; Type-2 information is only useful for inferring the random matrix, $W^{(l)}$; Type-3 information plays roles in inferring both $\tau_{in,z}^{-m}$ and $W^{(l)}$.

Proposition 1. In the privacy preserved algorithm for ATDM proposed above, the BLA cannot infer the indoor temperature information $\tau_{in,z}^{i,t}$ ($\forall i \in \mathbf{K}, \forall t \in \mathbf{T}$) based on type-1 information when K > L.

Proof. Based on the type-1 information, the inference equations for the BLA are

$$\tau_{in,z}^{-m}\xi^{(l)} = d_{1,m}^{(l)}, \ \forall m \in \mathbf{M}.$$
(16)

Here, (16) is essentially the aggregate temperature information from period 1 - M to T. Therefore, $\tau_{in,z}^{i,1-M}, \cdots, \tau_{in,z}^{i,T}$ ($\forall i \in \mathbf{K}$) are (T + M)K unknown variables. Correspondingly, the total number of equations for inference is (T + M)L. According to K > L, (T+M)K > (T+M)L can be derived, making (16) an under-determined equation system.

Then, we consider type-2 information because the matrix W also needs to be protected according to the previous discussion. Since all the parameters and variables in type-2 information are renewed during each iteration, we only need to consider whether W can be inferred during one particular iteration. Thus, we dismiss the iteration index when analyzing type-2 information $I_W^{(l)}$ for simplicity. Proposition 2 is a detailed elaboration.

Proposition 2. In the privacy-preserved algorithm in Section III, the BLA cannot infer the privacy inferences based on type-2 information when $K \ge 6$.

Proof. Based on the definition of type-2 information, the BLA can get the inference equations as

$$WW^T = D_1, (17a)$$

$$1^T W^T = d_2, \tag{17b}$$

$$\xi = W^T \bar{\xi},\tag{17c}$$

wherein the random matrix, W, has K^2 unknown variables. Note that the matrix, D_1 , is symmetric, so there is $\sum_{i=1}^{K} i$, i.e. K(K+1)/2 independent equations in (17a). (17b) and (17c) provides K equations, respectively. Considering (17a)-(17c) comprehensively, there are $\frac{1}{2}K^2 + \frac{5}{2}K$ equations for inference. When the condition $K \ge 6$ holds, we have $\frac{1}{2}K^2 + \frac{5}{2}K < K^2$, which means the equation system is under-determined and W cannot be inferred [30].

Proposition 1 and Proposition 2 imply that the BLA has to resort to type-3 information to make privacy inferences. The privacy inference problem is to solve an MQS problem once the BLA resorts to type-3 information as

$$\tau_{in,z}^{-m}\xi^{(l)} = d_{1,m}^{(l)}, \ \forall m \in \mathbf{M}, l \in \mathbf{L},$$
(18a)

$$W^{(l)}(W^{(l)})^T = D_1^{(l)}, \forall l \in \mathbf{L},$$
 (18b)

$$1^{T} (W^{(l)})^{T} = d_{2}^{(l)}, \forall l \in \mathbf{L},$$
(18c)

$$(W^{(l)})^T \bar{\xi}^{(l)} = \xi^{(l)}, \forall l \in \mathbf{L},$$
 (18d)

$$(\tau_{in,z}^{-0} - \sum_{m \in \mathbf{M} \setminus \{\mathbf{0}\}} \alpha_{bc}^m \tau_{in,z}^{-m}) (W^{(l)})^T = D_2^{(l)}, \forall l \in \mathbf{L}.$$
 (18e)

The equations (18a), (18c), and (18d) are linear equations, while the other two are quadratic ones, making (18) an MQS system. It is well known that the MQS problem is NP-hard, for which no polynomial-time algorithms exist [34], [35].

In addition, (18a)-(18e) provide (T+M)L, $\frac{1}{2}(k^2+k)L$, KL, KL, and TKL equations, respectively, while $\tau_{in,z}^{-m}$ ($\forall m \in \mathbf{M}$) and $W^{[l]}$ ($\forall l \in \mathbf{L}$) have (T+M)K and K^2L unknown variables, respectively. When the number of periods T is larger than the total number of building zones, K, the number of equations in (18) is larger than the number of unknown variables, making (18) an over-determined system. In this situation, we can only obtain the least squares solution of this over-determined system, which is a typical nonconvex optimization problem. Note that there are usually numerous local optima for this nonconvex problem, making it impossible to determine whether the obtained solution is right. In summary, the BLA can't infer the private information of the users. We will conduct further analysis and verification in simulations.

V. SIMULATION RESULTS

The data from the REFIT Smart Home dataset [36] is used to verify the effectiveness of the proposed privacy-preserved nonlinear parameter estimation method. Seven buildings with relatively complete data, namely No. 1, 8, 10, 11, 13, 16, and 20, are selected for simulation. In this dataset, the time resolution is 30 minutes, and the number of records is 1440. We divide the training set and the testing set according to the proportion of 3 to 1, i.e. 1080 records for the training set and 360 records for the testing set. The period of occupants' activities is assumed to be 24h, and thus T_{occ} is set to 48. Each element in the random matrix, W, is set to obey the normal distribution with a standard deviation of 0.1 and a mean of 0.1. We set the model order, M, as 2, and the penalty factor, λ , as 100 [7].



Fig. 3. Aggregation coefficients: (a) Values (privacy-preserved vs. nonprivacy-preserved algorithms); (b) Relative errors between privacy-preserved and non-privacy-preserved algorithms.

TABLE IESTIMATION RESULTS OF α , β , γ , θ

Method	Parameter	m=0	m=1	m=2	
Privacy- preserved	$egin{array}{c} lpha_m \ eta_m \ \gamma_m \ heta_m \end{array}$	/ 0.0295 0.0069 0.3906	1.4796 0.0249 -0.0057 0.0692	-0.4884 0.0042 0.0042 -0.1969	
Non- privacy- preserved.	$egin{array}{c} lpha_m \ eta_m \ \gamma_m \ heta_m \end{array}$	/ 0.0296 0.0066 0.3904	1.4804 0.0247 -0.0055 0.0692	-0.4892 0.0042 0.0040 -0.1972	

All the simulations are performed on a PC with an Intel i7 core and 32GB RAM. The programming is based on MATLAB R2022b and Yalmip [37]. Gurobi 10.0 is used to solve the quadratic programming problem. The iteration tolerance in the proposed algorithm is set as 10^{-6} .

In the following, we analyze the performance of the proposed privacy-preserved algorithm for ATDM from four aspects: calculation accuracy, masking performance, computation performance, and privacy security.

A. Accuracy Analysis

The parameter estimation results by the privacy-preserved and non-privacy-preserved algorithms are given in Fig. 3 and Table I. Obviously, the estimation results of the proposed privacy-preserved algorithm are highly close to the ones under the non-privacy-preserved algorithm, with the relative error smaller than 0.1%. The minor errors are possibly caused by the rounding error of the random matrix introduced by the TE method. Thus, the calculation accuracy of the privacypreserved algorithm for ATDM is well verified.

Then, we calculate some statistical indicators on the test set and compare them with the results without privacy protection to verify the accuracy of the algorithm. Here, three common statistical indicators are adopted: RMSE, MAPE, and R^2 . Their calculation formulas are shown as

$$\text{RMSE} = \sqrt{\frac{1}{T} \sum_{t=1}^{T} \left(\tilde{\tau}_{in,bc,pre}^{t} - \tilde{\tau}_{in,bc,real}^{t}\right)^{2}},$$



Fig. 4. Aggregate state and real indoor temperatures of zones.

TABLE II Error Indicators					
Indicator	RMSE(°C)	MAPE (%)	R ²		
Privacy-preserved Non-privacy-preserved	0.2944 0.2741	1.3103 1.2127	0.8613 0.8797		

$$\begin{split} \mathrm{MAPE} &= \frac{1}{T}\sum_{t=1}^{T} \mid \frac{\left(\tilde{\tau}_{in,bc,pre}^{t} - \tilde{\tau}_{in,bc,real}^{t}\right)}{\tilde{\tau}_{in,bc,real}^{t}} \mid, \\ \mathrm{R}^{2} &= 1 - \frac{\sum_{t=1}^{T} \left(\tilde{\tau}_{in,bc,pre}^{t} - \tilde{\tau}_{in,bc,real}^{t}\right)^{2}}{\sum_{t=1}^{T} \left(\tilde{\tau}_{in,bc,real}^{t} - 1/T\sum_{t=1}^{T} \tilde{\tau}_{in,bc,real}^{t}\right)^{2}}, \end{split}$$

wherein $\tilde{\tau}_{in,bc,pre}^t$ is the predicted aggregate state of the building cluster calculated according to (2d) and $\tilde{\tau}_{in,bc,real}^t$ is the real aggregate state of the building cluster calculated according to (2b).

The comparisons of these error indicators between the privacy-preserved and non-privacy-preserved algorithms are illustrated in Table II. It can be found that the privacy-preserved algorithm can fit well with RMSE, MAPE, and R^2 equal to 0.2944°C, 1.3103%, and 0.8613, respectively. Compared with the non-privacy-preserved algorithm, the accuracy of forecasting slightly decreased. In other words, the proposed privacy-preserved algorithm sacrifices a little prediction accuracy for excellent privacy-preservation performance.

Moreover, the real aggregate state and the predicted aggregate state of the building cluster under the privacy-preserved algorithm for ATDM are illustrated in Fig. 4. The results show that our proposed algorithm has excellent accuracy in both the training and test sets.

B. Masking Performance Analysis

To measure the performance of masking information, we compare the original data and masked data. We take the first column of the original $\hat{\tau}_{in,z}$ and its encryption version $\hat{\tau}_{in,z}W^T$ in all three iterations as an example as shown in Fig. 5. It is evident that the information, $\hat{\tau}_{in,z}$, is perfectly masked by the encryption matrix, W^T .

C. Computational Performance Analysis

Comparing the computing time under the privacy-preserved algorithm and the non-privacy-preserved algorithm for ATDM, problems of different scales are considered for comprehensive analysis. As shown in Table III, when the computation scale increases, the computation time increases regardless of whether privacy preservation is considered. In addition, the computing time is significantly longer when privacy preservation is considered. This is because the generation and operation of



Fig. 5. The first column of $\hat{\tau}_{in,z}$ and of sites encryption version $\hat{\tau}_{in,z}W^T$: (a) Iteration 1; (b) Iteration 2; (c) Iteration 3.

TABLE III COMPUTATION TIME AND ITERATIONS

No. of buildings	Num. of agents	Privacy-preser.		Non-privacy-preser.	
		Time (s)	Iter.	Time (s)	Iter.
1	10	0.2920	2	0.2763	2
1/8	19	0.6121	3	0.3784	3
1/8/10	27	1.0593	3	0.3865	3
1/8/10/11	37	2.100	3	0.4117	3
1/8/10/11/13	47	3.7237	3	0.4361	3
1/8/10/11/13/16	56	5.6593	3	0.4672	3
1/8/10/11/13/16/20	64	9.2325	3	0.4785	3

large numbers of random matrices take abundant time when the SAP and TE methods are implemented. This shows a tradeoff between the privacy preservation effect and the computing efficiency.

D. Privacy Security Analysis

In this part, we analyze the privacy inference problem numerically. The "fmincon" solver in Matlab is used to obtain the least squares solution of the MQS problem (18). We generate the component of $W^{(l)}(l \in \mathbf{L})$ and $\tau_{in,z}^{-m}$ using a normal distribution with a standard deviation of 1 and a mean of 20. Based on this, the constant matrices and vectors in (18) can be obtained. Then, the BLA can solve (18) and get the solution $\tau_{in,z,0}^{-m}$ and $W_0^{(l)}$. We can compare the differences between $\tau_{in,z}^{-m}$ and $\tau_{in,z,0}^{-m}$ to verify whether the BLA makes an accurate privacy inference. In our simulations, we set $K = 6, L = 3, T \in \{1, 2, 3, 4, 6, 12, 24, 48\}$, 8 cases in total. The initial point is critical in solving the MQS (18). We set 20 scenarios for each case, in which the initial point is set to the accurate value of $W^{(l)}(l \in \mathbf{L})$ plus random perturbations following a uniform distribution in [-1, -1].



Fig. 6. Privacy inference results: (a) Inference errors; (b) Computation time.

The inference errors are given in Fig. 6a. The solution time of each case is shown in Fig. 6b. Obviously, as the size of the MQS increases, the solution time increases exponentially. In practice, both T and K are significant numbers. Hence, we can conclude that obtaining the least squares solution of this MQS problem is impossible within an acceptable time.

In summary, the simulation results reveal that (i) the inaccurate initial point leads to huge inference errors and (ii) the computational cost of the MQS increases exponentially. More importantly, even if BLA coincidentally infers the correct values, it cannot determine whether it is true because determining whether a local optimum is a global optimum is still an NPhard problem for a nonconvex problem. Considering these points, the BLA cannot infer private information by solving the MQS problem (18).

VI. CONCLUSION

This paper proposes a privacy-preserved aggregate thermal dynamic model for the building cluster to provide an interface for the interaction between the energy system and buildings. The proposed privacy-preserved computation algorithm can estimate the parameters of the aggregate thermal dynamic model without exposing the privacy information of users. Simulation results based on real-world data demonstrate the excellent performance of the proposed method.

APPENDIX A PRIVACY DISCLOSURE CAUSED BY $\hat{\tau}_{in,z}$

This section illustrates why the indoor temperatures will be disclosed if $\hat{\tau}_{in,z}^{(l)}$ is known to the BLA. Based on the original definition of $\hat{\tau}_{in,z}$ in (9a), the BLA can have the inference equations about building zone $i \ (\forall i \in \mathbf{K})$ as

$$\hat{\tau}_{in,z}^{i,t,(l)} = \tau_{in,z}^{i,t} - \sum_{m=1}^{M} \alpha_m^{(l)} \tau_{in,z}^{i,t-m}, \quad t \in \mathbf{T}, l \in \mathbf{L}, \quad (A.1)$$

wherein there are (T + M) unknown variables, i.e. $\tau_{in,z}^{i,1-M}, \cdots, \tau_{in,z}^{i,T}$. On the other hand, there are TL linear equations during all iterations. Considering the model order M is usually a small integer like 2 or 3, the condition TL > T + M will hold as long as $L \ge 2$. Thus, the BLA can infer $\hat{\tau}_{in,z}^{i,t}$ ($\forall i \in \mathbf{K}, \forall t \in \mathbf{T}$) when $L \ge 2$. (The condition L > 2 is easy to satisfy in practical situations.)

APPENDIX B PRIVACY DISCLOSURE CAUSED BY W_i

This section proves that $W^{[i]}(W^{[i]})^T$ will disclose information of the random matrix $w_{i,j}$.

$$W^{[i]}(W^{[i]})^{T} = \begin{bmatrix} w_{1i}w_{1i} & \cdots & w_{1i}w_{Ki} \\ \vdots & \ddots & \vdots \\ w_{Ki}w_{1i} & \cdots & w_{Ki}w_{Ki} \end{bmatrix}.$$
 (B.1)

Once $W^{[i]}(W^{[i]})^T$ ($\forall i \in \mathbf{K}$) is known to the BLA, it can easily get the proportional relationship between $w_{1i}, w_{2i}, \dots, w_{Ki}$ based on the inference equation in (B.1).

$$w_{i1} = g_1 w_{i2} = g_2 w_{i3} = \dots = g_{K-1} w_{iK}, \ \forall i \in \mathbf{K},$$
 (B.2)

wherein g_1, g_2, \dots, g_{K-1} are known constants for the BLA. Moreover, during each iteration l, the BLA can acquire $\bar{\xi}$ calculated by itself and the recovered ξ transferred from building zones. Thus, the BLA can infer $W^{[i]}$ ($\forall i \in \mathbf{K}$) by jointly solving the equations (10a) and (B.2).

REFERENCES

- M. Bourdeau, X. qiang Zhai, E. Nefzaoui, X. Guo, and P. Chatellier, "Modeling and forecasting building energy consumption: A review of data-driven techniques," *Sustainable Cities and Society*, vol. 48, p. 101533, 2019.
- [2] Z. Pan, Q. Guo, and H. Sun, "Feasible region method based integrated heat and electricity dispatch considering building thermal inertia," *Applied energy*, vol. 192, pp. 395–407, 2017.
- [3] A. F. Taha, N. Gatsis, B. Dong, A. Pipri, and Z. Li, "Buildings-;grid integration framework," *IEEE Transactions on Smart Grid*, vol. 10, no. 2, pp. 1237–1249, 2019.
- [4] P. Zhao, G. P. Henze, M. J. Brandemuehl, V. J. Cushing, and S. Plamp, "Dynamic frequency regulation resources of commercial buildings through combined building system resources using a supervisory control methodology," *Energy and buildings*, vol. 86, pp. 137–150, 2015.
- [5] H. Fontenot and B. Dong, "Modeling and control of building-integrated microgrids for optimal energy management–a review," *Applied Energy*, vol. 254, p. 113689, 2019.
- [6] M. Song *et al.*, "State space modeling and control of aggregated tcls for regulation services in power grids," *IEEE Transactions on Smart Grid*, vol. 10, no. 4, pp. 4095–4106, 2018.
- [7] S. Lu *et al.*, "Data-driven aggregate thermal dynamic model for buildings: A regression approach," *IEEE Transactions on Smart Grid*, vol. 13, no. 1, pp. 227–242, 2021.
- [8] S. Zhan and A. Chong, "Data requirements and performance evaluation of model predictive control in buildings: A modeling perspective," *Renewable and Sustainable Energy Reviews*, vol. 142, p. 110835, 2021.
- [9] X. Li and R. Yao, "Modelling heating and cooling energy demand for building stock using a hybrid approach," *Energy and Buildings*, vol. 235, p. 110740, 2021.
- [10] A. Foucquier, S. Robert, F. Suard, L. Stéphan, and A. Jay, "State of the art in building modelling and energy performances prediction: A review," *Renewable and Sustainable Energy Reviews*, vol. 23, pp. 272– 288, 2013.
- [11] J. C. Lam, S. C. Hui, and A. L. Chan, "Regression analysis of high-rise fully air-conditioned office buildings," *Energy and Buildings*, vol. 26, no. 2, pp. 189–197, 1997.
- [12] S. A. Kalogirou, "Applications of artificial neural-networks for energy systems," *Applied energy*, vol. 67, no. 1-2, pp. 17–35, 2000.
- [13] M. K. Muthalib and C. O. Nwankpa, "Physically-based building load model for electric grid operation and planning," *IEEE Transactions on Smart Grid*, vol. 8, no. 1, pp. 169–177, 2016.
- [14] Z. Guo *et al.*, "Aggregation and data driven identification of building thermal dynamic model and unmeasured disturbance," *Energy and Buildings*, vol. 231, p. 110500, 2021.
- [15] C. Gonçalves, R. J. Bessa, and P. Pinson, "A critical overview of privacypreserving approaches for collaborative forecasting," *International journal of Forecasting*, vol. 37, no. 1, pp. 322–342, 2021.

- [16] S. Boyd *et al.*, "Distributed optimization and statistical learning via the alternating direction method of multipliers," *Foundations and Trends*® *in Machine learning*, vol. 3, no. 1, pp. 1–122, 2011.
- [17] Q. Ling and A. Ribeiro, "Decentralized dynamic optimization through the alternating direction method of multipliers," *IEEE Transactions on Signal Processing*, vol. 62, no. 5, pp. 1185–1197, 2013.
- [18] C. Zhang, M. Ahmad, and Y. Wang, "Admm based privacy-preserving decentralized optimization," *IEEE Transactions on Information Forensics and Security*, vol. 14, no. 3, pp. 565–580, 2018.
- [19] A. Alanwar et al., "Proloc: Resilient localization with private observers using partial homomorphic encryption," in *Proceedings of the 16th* ACM/IEEE International Conference on Information Processing in Sensor Networks, 2017, pp. 41–52.
- [20] Y. Mo and R. M. Murray, "Privacy preserving average consensus," *IEEE Transactions on Automatic Control*, vol. 62, no. 2, pp. 753–765, 2016.
- [21] G. Mateos, J. A. Bazerque, and G. B. Giannakis, "Distributed sparse linear regression," *IEEE Transactions on Signal Processing*, vol. 58, no. 10, pp. 5262–5276, 2010.
- [22] V. Dvorkin, F. Fioretto, P. Van Hentenryck, P. Pinson, and J. Kazempour, "Differentially private optimal power flow for distribution grids," *IEEE Transactions on Power Systems*, vol. 36, no. 3, pp. 2186–2196, 2020.
- [23] J. Wang, J. Tan, and J.-F. Zhang, "Differentially private distributed parameter estimation," *Journal of Systems Science and Complexity*, vol. 36, no. 1, pp. 187–204, 2023.
- [24] T. W. Mak, F. Fioretto, L. Shi, and P. Van Hentenryck, "Privacypreserving power system obfuscation: A bilevel optimization approach," *IEEE Transactions on Power Systems*, vol. 35, no. 2, pp. 1627–1637, 2019.
- [25] T. Wu, C. Zhao, and Y.-J. A. Zhang, "Privacy-preserving distributed optimal power flow with partially homomorphic encryption," *IEEE Transactions on Smart Grid*, vol. 12, no. 5, pp. 4506–4521, 2021.
- [26] Y.-R. Chen, A. Rezapour, and W.-G. Tzeng, "Privacy-preserving ridge regression on distributed data," *Information Sciences*, vol. 451, pp. 34– 49, 2018.
- [27] H.-Y. Tran and J. Hu, "Privacy-preserving big data analytics a comprehensive survey," *Journal of Parallel and Distributed Computing*, vol. 134, pp. 207–218, 2019.
- [28] N. Tian, Q. Guo, and H. Sun, "Privacy preservation method for miqpbased energy management problem: A cloud-edge framework," *Electric Power Systems Research*, vol. 190, p. 106850, 2021.
- [29] U. Karaca, Ş. İ. Birbil, N. Aydın, and G. Mullaoğlu, "Masking primal and dual models for data privacy in network revenue management," *European Journal of Operational Research*, vol. 308, no. 2, pp. 818– 831, 2023.
- [30] M. Jia, G. Hug, Y. Su, and C. Shen, "Chance-constrained opf: A distributed method with confidentiality preservation," *IEEE Transactions* on *Power Systems*, 2022.
- [31] M. Benzaama, L. Rajaoarisoa, B. Ajib, and S. Lecoeuche, "A data-driven methodology to predict thermal behavior of residential buildings using piecewise linear models," *Journal of Building Engineering*, vol. 32, p. 101523, 2020.
- [32] K. Yun, R. Luck, P. J. Mago, and H. Cho, "Building hourly thermal load prediction using an indexed arx model," *Energy and Buildings*, vol. 54, pp. 225–233, 2012.
- [33] K. Bonawitz et al., "Practical secure aggregation for privacy-preserving machine learning," in proceedings of the 2017 ACM SIGSAC Conference on Computer and Communications Security, 2017, pp. 1175–1191.
- [34] E. Thomae and C. Wolf, "Solving systems of multivariate quadratic equations over finite fields or: From relinearization to mutantxl," *Cryp*tology ePrint Archive, 2010.
- [35] S. Tanaka, C.-M. Cheng, and K. Sakurai, "Evaluating solving time of multivariate quadratic equation system using xl algorithm over small finite fields," 2014. [Online]. Available: https://api.semanticscholar.org/CorpusID:202617136
- [36] S. Firth et al., "REFIT Smart Home dataset," 6 2017. [Online]. Available: https://repository.lboro.ac.uk/articles/dataset/REFIT_Smart_Home_dataset/2070091
- [37] J. Löfberg, "Yalmip : A toolbox for modeling and optimization in matlab," in *In Proceedings of the CACSD Conference*, Taipei, Taiwan, 2004.