

Category	Methodology	Description	Strength	Weakness
Device	DVR [7], [8]	Add the missing voltage during a voltage sag	Injects a voltage in series with the system voltage	Can inject a voltage for a short time Unsuitable for systems with prolonged reactive power deficiencies
	D-STATCOM [9], [10]	Compensate the bus voltage so as to provide improved power factor and reactive power control	Generate the rated current at any network voltage Use of a relatively small capacitor on the DC bus Harmonic current compensation Load balancing	Generating the harmonics distortion Designed for FIDVR mitigation
Placement	Analytical [12]-[14]	Analytical method to determine the optimal location for placing DGs	Easy to implement	Only consider balanced systems A detailed 3-phase distribution system model is necessary
	Meta-heuristic [15], [16]	Application of particle swarm optimization for optimal DGs allocation and sizing	Simple to implement Less computational effort	
	Combination [17], [18]	Combining genetic algorithms with particle swarm optimization to determine the optimal location and sizing of DGs	Superior to the individual method in terms of solution quality and number of iterations	
Control scheme	IEEE 1547 [19]	Include the functionality of local regulation of voltages through inverter VVC	Simple design Easy implementation	Non-adaptability Not taking all the benefits of DVC
	Delayed VVC [20]	Actively adjusts its VAR output as a function of local bus voltage	Control stability	Cannot maintain a feasible voltage profile under certain circumstances
	Scaled VVC [21]	Feedback-based VVC strategy by means of a diagonally scaled gradient projection method	Control stability Set-point tracking	Requires full centralized topology information Theoretical analysis only builds on 1-phase
	Adaptive VVC [22]	Achieves both low steady state error and control stability, and makes control parameters self-adaptive to external disturbances	Achieve high set-point tracking accuracy and control stability Self-adaptive parameter selection	Considers the node voltage where the inverter is located, not the voltage profiles of the entire system
	Our method	Optimal dispatch, placement and control scheme for DVCs to minimize voltage variations and voltage regulator operations	Consider unbalanced 3-phase systems Practical dispatch scheme that overcomes the limitations of communication in distribution systems Consider the voltage variation of the entire system	Require short-term load and solar PV forecasting