

Indicative values for Net Transfer Capacities (NTC) in Europe
Summer 2004, working day, peak hours
(Preliminary and non-binding values)

FROM	TO	MW	VALUE PROVIDED BY
Albania	JIEL*	300 // 400	Albania // EKC
	Greece	250	Albania and Greece
Albania+Bulgaria+FYROM	Greece	600	Greece
Austria	Germany	1400	Austria and Germany
	Italy	available on 05/2004	Italy
	Czech Rep. + Hungary	1100	Austria
	Czech Rep.	600	Czech Rep.
	Germany + Switzerland	1900	Austria
	Germany + Switzerland ***	2900	Switzerland
	Hungary	300	Hungary
	Slovenia	650	Slovenia
Belgium	France	2500	Belgium and France
	Netherlands	2000	Belgium and Netherlands
Belgium + Germany	Netherlands	4700	Netherlands
Bosnia and Herzegovina	Croatia	100	Bosnia and Herzegovina (ZEKC)
Bulgaria	JIEL*	1100 // 900	Bulgaria // EKC
	Greece	400	Greece
	Romania	970 (*) // 1970 (**)	Bulgaria // Romania
Bulgaria+Albania+FYROM	Greece	600	Greece
Bulgaria + JIEL/EKCblock*	Romania	2390	Romania
Croatia	Bosnia and Herzegovina	300	Bosnia and Herzegovina (ZEKC)
	JIEL*	500	EKC
	Hungary	300	Hungary
	Slovenia	1000	Slovenia
Czech Rep.	Germany	2410 // 1700	Czech Rep. // Germany
	Austria	1210	Czech Rep.
	Poland	700	Czech Rep. and Poland
	Slovakia	1720 // 1200	Czech Rep. // Slovakia
Czech Rep. + Hungary	Austria	400	Austria
Czech Rep. + Slovakia + Germany	Poland	700	Poland
Czech Rep. + Poland	Germany	2300 // 2500	Germany // Poland
Denmark (West)	Germany	1200	Denmark and Germany
Denmark (East)	Germany	550	Denmark and Germany
Denmark (West)	Sweden	490	Denmark and Sweden
Denmark (East)	Sweden	1700	Denmark and Sweden
Denmark (West)	Norway	950	Denmark and Norway
Finland	Sweden	1600	Finland and Sweden
	Norway	100	Finland and Norway
FYROM	Greece	200	Greece
FYROM+Albania+Bulgaria	Greece	600	Greece

These indicative values have been computed by extrapolation from standard situations, in order to evaluate the transfer capacity through a single interface at the same time. Thus these figures should be considered separately and are not cumulative. When the evaluation of a transfer limit requires to use a set of assumption which are too far from usual or foreseeable situation (leading to high inaccuracies), the NTC figure has been replaced by « no realistic limit ».

FROM	TO		VALUE PROVIDED BY
France	United Kingdom	2000	France
	Belgium	1800	Belgium and France
	Germany	2100	France and Germany
	Belgium + Germany		France
	Italy	2400	France
	Switzerland	2400 // 4350	France // Switzerland
	Spain	1200	France and Spain
France+Switzerland	Italy		Austria-France-Italy-Slovenia-Switzerland
Greece	Albania	80 (1)	Greece
	Bulgaria	0 (1)	Greece
	Italy	0 (1)	Greece
	FYROM	0 (1)	Greece
(1) Regulated Capacities			
Germany	Austria	1200	Austria and Germany
	Netherlands	4000	Germany and Netherlands
	Czech Rep. + Poland	1000	Poland
	Czech Rep.	900	Czech Rep. and Germany
	Denmark (east)	550	Denmark and Germany
	Denmark (west)	800	Denmark and Germany
	France	4000	Germany
	Poland	700	Germany and Poland
	Sweden	370	Germany and Sweden
	Switzerland	4000	Germany and Switzerland
Germany and Switzerland	Austria	1600	Austria
Germany and Switzerland	Austria ***	1800	Switzerland
Hungary	Austria	700	Hungary
	Croatia	600	Hungary
	JIEL*	750	EKC
	Romania	700	Romania
	Slovakia	0 // 600	Hungary // Slovakia
Italy	France	<i>no realistic limit</i>	Italy
	Switzerland	<i>no realistic limit</i>	Italy
	Austria	<i>no realistic limit</i>	Italy
	Slovenia	<i>no realistic limit</i>	Italy
	Greece	500	Italy
JIEL*	Albania	400	Albania and EKC
	Bulgaria	500 // 550	EKC // Bulgaria
	Croatia	300	EKC
	Hungary	1000	EKC
	Romania	1500 // 1820	EKC // Romania
Morocco	Spain	400	Spain
Netherlands	Belgium	1900	Belgium and Netherlands
	Belgium + Germany	3700	Netherlands
	Germany	2900	Germany and Netherlands

These indicative values have been computed by extrapolation from standard situations, in order to evaluate the transfer capacity through a single interface at the same time. Thus these figures should be considered separately and are not cumulative. When the evaluation of a transfer limit requires to use a set of assumption which are too far from usual or foreseeable situation (leading to high inaccuracies), the NTC figure has been replaced by « no realistic limit ».

FROM	TO		VALUE PROVIDED BY
Norway	Denmark (West)	1000	Norway and Denmark
	Sweden	3350	Norway and Sweden
	Finland	70	Norway and Finland
Poland	Czech Rep. + Slovakia + Germany	2000	Poland
	Czech Rep.	1920	Czech Rep. and Poland
	Germany	1100	Germany and Poland
	Sweden	600	Poland and Sweden
Portugal	Spain	550	Portugal and Spain
Republic of Ireland	United Kingdom	0	Republic of Ireland
Romania	JIEL*	1000 // 1580	EKC // Romania
	Bulgaria	830 (*) // 2230 (**)	Bulgaria/Romania
	Bulgaria + JIEL*	2710	Romania
	Hungary	1650	Romania
	Slovakia and Ukraine	1530	Romania
Russia	Finland		Finland
Slovakia	Czech Rep.	800 // 1200	Czech Rep. // Slovakia
	Hungary	1110 // 850	Hungary // Slovakia
	Poland	700 // 450	Poland // Slovakia
	Ukraine	450	Slovakia
Slovenia	Austria	650	Slovenia
	Croatia	1000	Slovenia
	Italy	availalbe on 05/2004	Italy
Spain	Portugal	600	Portugal and Spain
	France	700	France and Spain
	Morocco	400	Spain
Sweden	Germany	460	Germany and Sweden
	Denmark (West)	460	Sweden and Denmark
	Denmark (East)	1300	Sweden and Denmark
	Finland	2000	Sweden and Finland
	Norway	3050	Sweden and Norway
	Poland	600	Poland
Switzerland	Austria	no realistic limit	
	Germany	3000	Germany and Switzerland
	France	no realistic limit	
	Italy	availalbe on 05/2004	Italy
Ukraine	Romania	870	Romania
	Slovakia	450	Slovakia
United Kingdom	France	2000	United Kingdom
	Republic of Ireland	330	Republic of Ireland

* JIEL block - Serbia, Montenegro.

** NTC values between JIEL block and EPS of BiH are not calculated due to the existence of three independent islands in EPS of BiH.

*** These values pertain to the political borders and not to the limits of the control areas.

These indicative values have been computed by extrapolation from standard situations, in order to evaluate the transfer capacity through a single interface at the same time. Thus these figures should be considered separately and are not cumulative. When the evaluation of a transfer limit requires to use a set of assumption which are too far from usual or foreseeable situation (leading to high inaccuracies), the NTC figure has been replaced by « no realistic limit ».