

Indicative values for Net Transfer Capacities (NTC) in Europe
Winter 2001 - 2002, working day, peak hours
(Non binding values)

October 2001

FROM	TO	MW	VALUE PROVIDED BY
Albania	Greece		<i>Data not available</i>
Austria	Germany	1150	Germany
	Italy	220	Italy
	Centrel	2000	Austria
	Italy + Slovenia	850	Austria
	Germany + Switzerland	3000	Austria and Switzerland
Austria + Slovenia	Italy	600	Italy
Belgium	France	3100	Belgium
	Netherlands	1700	Belgium and Netherlands
Belgium + Germany	Netherlands	3600	Netherlands
Bulgaria	Greece		<i>Data not available</i>
Centrel	Austria	1400	Austria
	Germany	2250	Germany
Denmark (West)	Germany	1200	Denmark and Germany
Denmark (East)	Germany	550	Denmark and Germany
Denmark (West)	Sweden	610	Denmark and Sweden
Denmark (East)	Sweden	1700	Denmark and Sweden
Denmark (West)	Norway	950	Denmark and Norway
Finland	Sweden	1650	Finland and Sweden
	Norway	100	Finland and Norway
France	Great Britain	2000	France and Great Britain
	Belgium	2200	Belgium
	Germany	2850	Germany
	Belgium + Germany	3750	France
	Italy	2200	Italy
	Switzerland + Italy	4950	France
	Spain	1100	France and Spain
France+Switzerland	Italy	5400	Switzerland, France and Italy

These indicative values have been computed by extrapolation from standard situations, in order to evaluate the transfer capacity through a single interface at the same time. Thus these figure should be considered separately and are not cumulative. When the evaluation of a transfer limit requires to use a set of assumption which are too far from usual or foreseeable situation (leading to high inaccuracies), the NTC figure has been replaced by « no realistic limit »

FROM	TO	MW	VALUE PROVIDED BY
FYROM	Greece		Data not available
Greece	Albania		Data not available
	FYROM		Data not available
	Bulgaria		Data not available
Germany	Austria	1650	Germany
	Switzerland	2000	Germany and Switzerland
	France	2250	Germany
	Denmark (west)	800	Germany and Denmark
	Sweden	370	Germany and Sweden
	Denmark (east)	550	Germany and Denmark
	Netherlands	2800	Germany and Netherlands
	Centrel	1200	Germany
Great Britain	France	2000	France and Great Britain
Italy	Austria + Slovenia	<i>no realistic limit</i>	
	France + Switzerland	<i>no realistic limit</i>	
	Switzerland	<i>no realistic limit</i>	
Italy + Slovenia	Austria	1050	Austria
Morocco	Spain	300	Spain
Netherlands	Belgium	1700	Netherlands
Netherlands	Belgium + Germany	3600	Netherlands
Netherlands	Germany	1350	Germany
Netherlands + Belgium	Germany	1700	Netherlands
Northern Ireland	Republic of Ireland	120	Republic of Ireland
Norway	Denmark (West)	1000	Norway and Denmark
	Sweden	2400	Norway and Sweden
	Finland	70	Norway and Finland
Portugal	Spain	725	Portugal and Spain
Republic of Ireland	Northern Ireland	50	Republic of Ireland
Russia	Finland	900	Finland
Slovenia	Italy	380	Italy

These indicative values have been computed by extrapolation from standard situations, in order to evaluate the transfer capacity through a single interface at the same time. Thus these figure should be considered separately and are not cumulative. When the evaluation of a transfer limit requires to use a set of assumption which are too far from usual or foreseeable situation (leading to high inaccuracies), the NTC figure has been replaced by « no realistic limit ».

FROM	TO	MW	VALUE PROVIDED BY
Spain	Portugal	850	Spain and Portugal
	France	1000	France and Spain
	Morocco	350	Spain
Sweden	Germany	460	Sweden and Germany
	Denmark (West)	580	Sweden and Denmark
	Denmark (East)	1300	Sweden and Denmark
	Finland	2050	Sweden and Finland
	Norway	2400	Sweden and Norway
	Centrel	600	Sweden
Switzerland	Austria	<i>no realistic limit</i>	Switzerland
	Germany	2000	Germany
	France	<i>no realistic limit</i>	Switzerland
	Italy	3100	Italy
Switzerland + Germany	Austria	2000	Switzerland and Austria

These indicative values have been computed by extrapolation from standard situations, in order to evaluate the transfer capacity through a single interface at the same time. Thus these figure should be considered separately and are not cumulative. When the evaluation of a transfer limit requires to use a set of assumption which are too far from usual or foreseeable situation (leading to high inaccuracies), the NTC figure has been replaced by « no realistic limit ».